

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0559:138

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Silent Knight Security, 7550 Meridian Cr., Maple Grove MN 55369
Contact: Brian Foltz (763) 493-6400 FAX (763) 493-6475*

DESIGN: Models SD-505-6SB and SD-505-6RB detector bases. Model SD-505-6SB employs an integral supplemental sounder. This sounder is NOT intended for use as a required audible device. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as detector bases for use with *listee's separately listed compatible fire alarm control units. *Refer to listee's Installation Instruction Manual for details.

*Rev. 10-07-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 7, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**